



| | | | | | |
|--------------------------------------|--|--|--|--|--|
| NUMAR CAMIN | CM88 | CMp1 | CBY | CMp2 | CG |
| COTE TEREN | 108.73 | 108.80 | 108.91 | 108.92 | 109.20 |
| COTA GENERATOARE SUPERIOARA CONDUCTA | 105.78 | 105.71 | 105.77 | 105.75 | 105.52 |
| COTE RADIER | 105.38 | 105.31 | 105.28 | 105.26 104.82 105.03 | 105.02 |
| DIST. PARTIALE | 24 | 12,0 | 5,6 | 3,0 | |
| DIST. CUMULATE | 0,00 | 24,00 | 36,00 | 41,60 | 44,60 |
| ACOPERIRE CONDUCTA | 3,35 | 3,1 | 3,14 | 3,17 | 3,68 |
| CARACTERISTICI | Tub PVC DN400 SN4 $i = 0,003$ (3 ‰) | Tub PVC DN400 SN4 $i = 0,003$ (3 ‰) | Tub PVC DN500 SN4 $i = 0,003$ (3 ‰) | Tub PEHD DN500 PE80 $i = 0,003$ (3 ‰) | Tub PVC DN500 SN4 $i = 0,003$ (3 ‰) |



| | | | | | |
|--|----------------------|--|--|--|--|
| S.C.COMPANIA DE APA ARAD S.A. Atelierul de Proiectare 310178 Arad str. Sabin Dragoi nr. 2 - 4 Tel: +40 257 270843 Fax: +40 257 270981 E-mail: apacanal@caarad.ro CF: R-1683483 Nr. ORC: J02/110/21.02.1991 | | | STATIE DE POMPARE APE UZATE SI CONDUCTA REFULARE STRADA CONSTITUTIEI, MUNICIPIUL ARAD | | Pr. nr. 10806/ 2013 Faza: PT |
| Sef atelier proiectare | ing. Breje Daniel | | Scara: 1:50 1:100 | Denumire planșă: Colector menajer Dn400 Colector menajer Dn500 Profil longitudinal | Pl. nr. 03-Ed. |
| Proiectat | ing. Ștyaszni Dan-Șt | | Data: August 2013 | | Rev. 0 |
| Desenat | ing. Ștyaszni Dan-Șt | | | | |
| Verificator intern | ing. Forgacs Gyorgy | | | | |